

Display Energy Certificate

How efficiently is this building being used?

Parliamentary Estates Directorate
1, Millbank
LONDON
SW1P 3JU

Certificate Reference Number:
9198-1043-0253-0100-2201

This certificate indicates how much energy is being used to operate this building. The operational rating is based on meter readings of all the energy actually used in the building. It is compared to a benchmark that represents performance indicative of all buildings of this type. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Operational Rating

This tells you how efficiently energy has been used in the building. The numbers do not represent actual units of energy consumed; they represent comparative energy efficiency. 100 would be typical for this kind of building.

More energy efficient

A 0-25

B 26-50

C 51-75

D 76-100

..... 100 would be typical

E 101-125

F 126-150


G Over 150

Less energy efficient

154


Total CO₂ Emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.



Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods.



Technical Information

This tells you technical information about how energy is used in this building. Consumption data based on actual meter readings.

Main heating fuel: Natural Gas
Building environment: Heating and Natural Ventilation
Total useful floor area (m²): 9044
Asset Rating: Not available

	Heating	Electricity
Annual Energy Use (kWh/m ² /year)	106	173
Typical Energy Use (kWh/m ² /year)	118	95
Energy from renewables	0.0%	0.0%

Administrative Information

This is a Display Energy Certificate as defined in SI 2007/991 as amended.

Assessment Software: TEAM, Sigma DEC, v3.6
Property Reference: 183221490000
Assessor Name: Mr Giles Davies
Assessor Number: NHER008588
Accreditation Scheme: National Energy Services Ltd
Employer/Trading Name: TEAM (Energy Auditing Agency Ltd)
Employer/Trading Address: 34 The Forum, Rockingham Drive, Milton Keynes, MK14 6LY

Issue Date: 02-05-2016
Nominated Date: 30-06-2016
Valid Until: 29-06-2017
Related Party Disclosure: Contractor to the occupier for EPBD services only.

Recommendations for improving the energy efficiency of the building are contained in the accompanying Advisory Report.